



Herewith it is confirmed to the company

EURAPO S.r.l.

in

I-33170 Pordenone

for the factory in
I-33170 Pordenone

based on the positive results of the inspection of one
fan coil unit of the ranges

“SV xxx – xxx ONORM H 6020 xxx” / “SH xxx – xxx ONORM H 6020 xxx”
“ESTSV xxx – xxx ONORM H 6020 xxx” / “ESTSH xxx – xxx ONORM H 6020 xxx”
“CV xxx – xxx ONORM H 6020 xxx” / “CH xxx – xxx ONORM H 6020 xxx”
“ESTCV xxx – xxx ONORM H 6020 xxx” / “ESTCH xxx – xxx ONORM H 6020 xxx”

according to the standard
VDI 6022 part 1: 2018-01

VDI/ÖFR 6022 part 1.1: 2024-07


VDI 3803 part 2: 2019-06

ÖNORM H 6020: 2024-03 *1

SWKI VA 104-01: 2019-01

that the requirements of the Certification Program of the
TÜV SÜD Industrie Service GmbH are fulfilled.

The manufacturer is allowed to use the following TÜV SÜD Certification Mark.



This certificate is valid until 2026-12-31

Certificate Registration Number: 24/21/109



Certification Body for Products
Refrigeration and Air-Conditioning
Munich, 2024-12-19



*1 Only suitable for rooms of classes 3 and 4 with dry cooling and with wet cooling if there is no requirement for an outlet-side filter.