

Herewith it is confirmed to the company

EURAPO S.r.I.

I-33170 Pordenone

for the factory in I-33170 Pordenone

based on the positive results of the inspection of one fan coil unit of the ranges

"UCS/HM 6xx- xxx – VDI 6022 xxx" "ESTUCS/HM 6xx - xxx - VDI 6022 xxx

> according to the standard VDI 6022 part 1: 2018-01 VDI/OFR 6022 part 1.1: 2024-07 VDI 3803 part 2: 2019-06 ÖNORM H 6020: 2024-03 *1 SWKI VA 104-01: 2019-01

that the requirements of the Certification Program of the TÜV SÜD Industrie Service GmbH are fulfilled.

The manufacturer is allowed to use the following TÜV SÜD Certification Mark.



Compliance with hygienic requirements (used materials/ accessibility/cleanability) acc. to:

- VDI 6022-1
- VDI/ÖFR 6022-1.1
- VDI 3803-2
- SWKI 104-01
- ÖNORM H 6020

www.tuvsud.com/kaelte-klima

This certificate is valid until 2026-12-31

Certificate Registration Number: 18/21/75 (Revision 02)



Certification Body for Products Refrigeration and Air-Conditioning Munich, 2024-12-19



¹ Only suitable for rooms of classes 3 and 4 with dry cooling and with wet cooling if there is no requirement for an outlet-side filter.